



Office of the Executive Engineer
F.M. Division-1. Dhaka WASA
29, K.M Das Lane, Hatkhola, Dhaka-1203.

Performance Test Report

Name of Work: Repairing of Axial Thrust Bearing for submersible Pump-motor set under F.M.Division-1 কাজের আওতায় সম্পাদিত কাজের পারফরমেন্স রিপোর্ট।

Name of Contractor: M/S, Ma Electrical Engineering


Contract No: DWASA/FMD-1/Contract-2025-26/06, Date: 16/09/2025.


Work Order No: 46.113.423.00.00.088-2025, Date: 16/09/2025.

Date of Test: 15/01/2026-27/01/2026

The following submersible Pump-Motor has been operated using repaired Axial Thrust Bearing:

Sl No	Pump Capacity	Production (LPM)	Voltage (V)	Current (A)	Remarks
01	1.5/110	2250	405 V	120 A	Satisfactory
02	1.5/110	2400	398 V	122 A	Satisfactory
03	1.5/125	2380	408 V	125 A	Satisfactory
04	1.0/110	1750	397 V	90 A	Satisfactory
05	1.5/125	2350	410V	120 A	Satisfactory


26/01/2026
Md. Mosabberul Alam
Sub-Assistant Engineer
F M Division-1
Dhaka WASA


26/01/2026
Md. Golam Mostafa
Assistant Engineer
F M Division-1
Dhaka WASA


26/01/2026
Md. Nawshad Alam
Executive Engineer
F M Division-1
Dhaka WASA