

Work Completion Report

Name of the Work: Maintenance of chlorine battery header line pneumatic actuator valve.

Name of the Contractor: M/S Ety International.

Estimated Amount: 49,600/-

Contract Amount: 49,600/-

Work order No. & Date: 46.113.635.00.00.2024-25.193.714, Date: 28/05/2025

Working Period: 07 Days

Actual Starting Date: 28-05-2025

Work Completion Date: 01-06-2025

Description of Executed Work:

SI No.	Description of Work	Qty.
1	Servicing & maintenance of chlorine battery header line pneumatic actuator valve (0.5 inch) with piston o-ring, side cover o-ring, shaft o-ring penium, guider, lock spring, head cap, piston guider & SS Bolt	07 Nos.
2	Supply & Installation of Nipple Male female 10-mm	50 Nos.

This work is completed as per specification & direction of Engineer in charge and within schedule time. Work completion report could be accepted.


01.06.25
এইচ এম নূর হক অপু
সিএমএমএস কো-অর্ডিনেটর
সাপাশো ফেজ-২ (ওএন্ডএম) বিভাগ
ঢাকা ওয়াশা।


01.06.25
মোঃ রাকিব হোসেন প্রধান
সহকারী প্রকৌশলী
সাপাশো ফেজ-২ (ওএন্ডএম) বিভাগ
ঢাকা ওয়াশা

Accepted.

সুজন চন্দ্র বরান
নির্বাহী প্রকৌশলী
সাপাশো ফেজ-২ (ওএন্ডএম) বিভাগ
ঢাকা ওয়াশা