



ঢাকা পানি সরবরাহ ও পয়ঃ নিষ্কাশন কর্তৃপক্ষ

নির্বাহী প্রকৌশলীর কার্যালয়
সংগ্রহ বিভাগ-২, ওয়াসা ভবন (৬ষ্ঠ তলা),
৯৮, কাজী নজরুল ইসলাম এভিনিউ, কাওরান বাজার, ঢাকা-১২১৫।

WebSite: www.dwasa.org.bd Phone: 41010230

কারিগরি পরীক্ষণ ও গ্রহন কমিটি রিপোর্ট

চুক্তি নং-	৪৬.১১৩.৪২৮.০০.০০.১০৪/২৫-২৬/সিএ-২৮	তারিখঃ ১২/০৪/২০২৬ ইং।
সরবরাহ আদেশ স্মারক নং-	৪৬.১১৩.৪২৮.০০.০০.১০৪.২০২৬-৮৫৩	তারিখঃ ২৩/০৪/২০২৬ ইং।
কাজের নাম	Procurement of 25mm (DN-25) Domestic Water Meter for Dhaka WASA (Lot-1)।	
সরবরাহকারীর নাম	এএমজেড ইনকর্পোরেট, ৫৪ আর কে মিশন রোড, সূত্রাপুর, ঢাকা-১২০৩।	
ক্রয়কারী বিভাগ	সংগ্রহ বিভাগ-০২।	
ব্যবহারকারী বিভাগের নাম	ঢাকা ওয়াসার বিভিন্ন বিভাগ।	
সরবরাহের স্থান	ঢাকা ওয়াসার কেন্দ্রীয় ভান্ডার, পাগলা।	
সরবরাহের তারিখ	২৩/০৬/২০২৬ ইং।	যৌথ পরিদর্শনের তারিখঃ ২৫/০৬/২০২৬ ইং।

ক্র. নং.	মালামালের বিবরণ	চুক্তি অনুযায়ী মালামালের পরিমাণ	একই কিস্তিতে দেয় মালামালের পরিমাণ	Country of Origin
1	25mm (DN-25) diameter water meter.	4,880 (Four thousand Eight hundred Eighty) Nos	4,880 (Four thousand Eight hundred Eighty) Nos	China

কারিগরি পরীক্ষণ ও গ্রহন কমিটি কর্তৃক সমুদয় মালামাল পরিদর্শন করা হইল এবং তা বাহ্যিকভাবে সঠিক পাওয়া গেল। বাহ্যিকভাবে সঠিক পাওয়ায় টেস্টের জন্য নমুনা সংগ্রহ করা হইল। জেনারেটর বিভাগ, ঢাকা ওয়াসা হইতে প্রাপ্ত পারফরম্যান্স টেস্ট রিপোর্টের ভিত্তিতে সমুদয় মালামাল চূড়ান্তভাবে গ্রহণ/বাতিলের সুপারিশ করা হইবে।


25.06.26


মোঃ মাজহারুল ইসলাম
নির্বাহী প্রকৌশলী
সংগ্রহ বিভাগ-২, ঢাকা ওয়াসা

ও সদস্য-সচিব,
কারিগরি পরীক্ষণ ও গ্রহন কমিটি

Rule


25.06.26

সাইমুল হক
উপ-বিভাগীয় প্রকৌশলী,
সংগ্রহ বিভাগ-২, ঢাকা ওয়াসা
ও সদস্য,
কারিগরি পরীক্ষণ ও গ্রহন কমিটি।


25.6.26

মোঃ আঃ লতিফ
তত্ত্বাবধায়ক প্রকৌশলী
আর.পি.ই. এন্ড এম সার্কেল,
ঢাকা ওয়াসা ও আস্থায়ক
কারিগরি পরীক্ষণ ও গ্রহন কমিটি।

স্মারক নং-৪৬.১১৩.৪৩৮.০০.০০.২০২৬-৩২১, তারিখঃ ৩০/০৬/২০২৬ইং; মোতাবেক মিটার বিভাগ, ঢাকা ওয়াসা হতে প্রাপ্ত পারফরম্যান্স টেস্ট রিপোর্টটি সন্তোষজনক। পারফরম্যান্স টেস্ট রিপোর্ট সন্তোষজনক পাওয়ায় সরবরাহকৃত সমুদয় মালামাল কারিগরি পরীক্ষণ ও গ্রহন কমিটি কর্তৃক চূড়ান্তভাবে গ্রহণের সুপারিশ করা হ'ল।


30.06.26

মোঃ মাজহারুল ইসলাম
নির্বাহী প্রকৌশলী
সংগ্রহ বিভাগ-২, ঢাকা ওয়াসা
ও সদস্য-সচিব,
কারিগরি পরীক্ষণ ও গ্রহন কমিটি


Rule


30.06.26

সাইমুল হক
উপ-বিভাগীয় প্রকৌশলী,
সংগ্রহ বিভাগ-২, ঢাকা ওয়াসা
ও সদস্য,
কারিগরি পরীক্ষণ ও গ্রহন কমিটি।


30.6.26

মোঃ আঃ লতিফ
তত্ত্বাবধায়ক প্রকৌশলী
আর.পি.ই. এন্ড এম সার্কেল,
ঢাকা ওয়াসা ও আস্থায়ক
কারিগরি পরীক্ষণ ও গ্রহন কমিটি।



নির্বাহী প্রকৌশলীর কার্যালয়

মিটার বিভাগ, ঢাকা ওয়াসা।

৪/৪, সেগুন বাগিচা, ঢাকা-১০০০।

e-mail: meterdwsa@gmail.com

স্মারক নং-৪৬.১১৩.৪৩৮.০০.০০.২০২৬-৩২১

তারিখ : ১৬ আষাঢ় ১৪৩৩

৩০ জুন ২০২৬

নির্বাহী প্রকৌশলী
সংগ্রহ বিভাগ-২
ঢাকা ওয়াসা।



বিষয় : ০২ (দুই) টি পানির মিটারের পারফরমেন্স টেস্ট রিপোর্ট প্রদান প্রসঙ্গে।

সূত্র : স্মারক নং : ৪৬.১১৩.৪২৮.০০.০০.১০৪.২০২৬-১১২৬, তারিখ : ২৫/০৬/২০২৬।

উপরোক্ত বিষয় ও সূত্রের প্রেক্ষিতে জানানো যাচ্ছে যে, সংগ্রহ বিভাগ-২ হতে Procurement of 25 mm (DN-25) diameter domestic water meter for Dhaka WASA (Lot-1) শীর্ষক সংগ্রহ কাজের আওতায় সরবরাহকৃত পানির মিটার হতে ০২ (দুই) টি পানির মিটারের পারফরমেন্স টেস্ট করে রিপোর্ট প্রদানের অনুরোধ জানান। সেই প্রেক্ষিতে সংগ্রহ বিভাগ-২ এর চাহিদা মোতাবেক ২৫ মিঃ মিঃ ০২ (দুই) টি পানির মিটার টেস্ট কার্যক্রম শেষ করা হয়েছে।

এমতাবস্থায়, সরবরাহকৃত ০২ (দুই) টি পানির মিটারের পারফরমেন্স টেস্ট রিপোর্ট পরবর্তী কার্যক্রমের জন্য এতদসঙ্গে প্রেরণ করা হলো।

SDE/AE
30.06.2026

মোঃ মাহবুব হাসান
নির্বাহী প্রকৌশলী
মিটার বিভাগ
ঢাকা ওয়াসা।

সংযুক্তি :

১। মিটার টেস্ট রিপোর্ট ১ সেট, (২৫ মিঃ মিঃ ০২ টি মিটার)।

সদয় অবগতির জন্য অনুলিপি প্রেরণ করা হলো :

- ১। উপ-ব্যবস্থাপনা পরিচালক (ও.এন্ড.এম), ঢাকা ওয়াসা।
- ২। প্রধান প্রকৌশলী, ঢাকা ওয়াসা।
- ৩। প্রধান রাজস্ব কর্মকর্তা, ঢাকা ওয়াসা।
- ৪। তত্ত্বাবধায়ক প্রকৌশলী, (এস.এম.ডব্লিউ.সি) সার্কেল, ঢাকা ওয়াসা।
- ৫। উপ-সহকারী প্রকৌশলী, মোঃ রিয়াজ উদ্দীন টিটু, সংগ্রহ বিভাগ-২, ঢাকা ওয়াসা।
- ৬। অফিস কপি।

METER DIVISION, DHAKA WASA

AIMEI Water Meter Test Report (Model-MD-K)

Allowable Error Limit (%) : $\pm 2\%$ For Q_n , $\pm 5\%$ For Q_t , & $\pm 5\%$ For Q_{min}

25 mm		Q_n			Q_t			Q_{min}			Comments
SL	Meter No	IMR	FMR	Actual Error (%)	IMR	FMR	Actual Error (%)	IMR	FMR	Actual Error (%)	
1	2026065530	220.2	320.9	0.7%	320.9	340.7	-1%	340.7	350.4	-3%	Satisfactory
2	2026064073	461.5	561.9	0.4%	561.9	581.4	-2.5%	581.4	590.9	-5%	Satisfactory

১০/৫/১৮
মোঃ আব্দুল্লাহ আলম
যেষ্ঠাধিক
মিটার ওয়ার্কশপ মিটার বিভাগ
ঢাকা ওয়াশা

১০/৫/১৮
মোঃ আব্দুল্লাহ আলম
যেষ্ঠাধিক
মিটার ওয়ার্কশপ মিটার বিভাগ
ঢাকা ওয়াশা

১০/৫/১৮
মোঃ আব্দুল্লাহ আলম
যেষ্ঠাধিক
মিটার ওয়ার্কশপ মিটার বিভাগ
ঢাকা ওয়াশা



Inspection Report

(Non-negotiable)

SDE/AE

10.06.2026

Inspector: **Angus Zhou**

Inspection location: **Ningbo City, Zhejiang Province, China**

Date of inspection: **Jun. 02, 2026**



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC (Shanghai) Technical Services Co., Ltd.
Industries Service

No.1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

Contents

1. Background information	3
2. Instrument.....	4
3. Quantity check.....	4
4. Marking check	5
5. Visual quality check	6
6. Dimension check.....	7
7. Witness testing.....	7
8. Document review.....	9
9. Photos.....	11



SGS-CSTC Inspection & Testing Services (Ningbo) Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

1. Background information

SGS order No.:	NBINSCS2600216				
Coordinator:	Fennie Feng	Telephone:	+86-0574-89070184		
Description of commodity (Name, Model, Quantity ...)					
MD-K DN25 1", multi jet Super-dry type water meter, brass body (CC770S),260mm length (meter body), Copper can register with 5mm glass, IP68, Q3: 6.3m3/h, R160-H, MAP16, MID Certificate. pulse output: 1L/pulse. With 2 meters AMR cable and brass connectors					
			4880 pcs		
5% Spare Parts. (Complete Mechanism 250 pcs. including Register + Vane Wheel + Chamber.)					
			250pcs		
Buyer (Name, Address...)					
AMZ Incorporate Address: 54, R.K. Mission Road, Sutrapur, Dhaka-1203, Bangladesh End User: Procurement Division-2, Dhaka WASA. Contract Number: 46.113.428.00.00.104/25-26/CA-28					
Seller (Name, Address...)					
NINGBO AIMEI METER MANUFACTURE CO., LTD. Address: 68, WEST TOWN ROAD, SHANGTIAN TOWN, FENGHUA CITY, ZHEJIANG PROVINCE, CHINA-315511					
P/I No.	AMFY26AMZ414, date: April 14,2026				
LC No.	350226010296				
Others	/				
Nature of inspection:	Item	Satisfactory		Non conforming	
	Quantity check (not include weight check)	●			
	Item	Satisfactory	Non conforming	Rejected	Subject to buyer's evaluation
	Marking check	●			
	Visual quality check	●			
	Dimension check	●			
	Witness test	●			
	Document review	●			



SGS-CSTC Shanghai Technical Service Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

2. Instrument

During the inspection, the following instrument calibration status has been checked for inspection:

No.	Name	ID No.	Measuring range	Calibrated ^[1] (Yes/No/NA)	Certificate NO.
1	Caliper	B17732921	0-300mm	Yes	XGH202509050071W
2	Thread gauge	AM-HG-003	G1-1/4-11	Yes	1325I02752
3	Pressure gauge	18031861	0-4MPa	Yes	XGH20250905100W
4	Difference pressure gauge	S4N405013315	EJA110A	Yes	XGH20250905107W
5	Water meter calibration equipment	120301	LBJ(15-50)	Yes	LL308241218002
6	Water meter calibration equipment	362-1	LS-3B	Yes	LL308250911005
7	Tape measurement	/	0-5m	No	/

[1] Calibrated

--- "Yes" means the instrument was calibrated and now is in the period of validity.

--- "No" means the instrument should be calibrated, in fact it was never calibrated or not calibrated before the expiry date.

--- "NA" means the instrument does not need to be calibrated in the view of its function.

3. Quantity check

3.1. Reference documents:

→ PI No. AMFY26AM414, date: April 14,2026

3.2. Method of quantity check

→ [Total package counting]

→ [check on the quantity within the selected packages]

No.	Description	REQ. quantity (pcs)	ACT. Quantity (pcs)	Remark
1	MD-K DN25 1", multi jet Super-dry type water meter, brass body (CC770S),260mm length (meter body), Copper can register with 5mm glass, IP68, Q3: 6.3m ³ /h, R160-H, MAP16, MID Certificate. pulse output: 1L/pulse. With 2 meters AMR cable and brass connectors	4880pcs	4880pcs	976cartons
2	5% Spare Parts. (Complete Mechanism 250 pcs. including Register+Vane Wheel + Chamber.)	250pcs	250pcs	5cartons

Note: the quantity is confirmed.



SGS-CSTC (China) Technical Services (Ningbo) Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

4. Marking check

- Sample size: [10samples]
- Reference document: PI No. AMFY26AMZ414, date: April14,2026

Marking in body of meter:




One side




Another side

Marking in dial of meter:



Marking in dial



Details of dial



SGS-CSTC Shanghai Technical Service Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.


This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040


t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com



Dials as spare part

Marking in seal

Marking in package:



Marking in carton

Remark: the main information of marking in dial is according with product description in PI and the result is satisfactory.

5. Visual quality check

→ Sample size: [10samples]

During this inspection, total 10samples were randomly selected for visual quality check.

- All samples have blue coating.
- The dial could rotate 360°
- The meter was sealed well.
- The inlet has a plastic strainer.
- No visible defect was found.

Remark: the result is satisfactory.



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.
This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040
t (86-574) 8776 7006 www.sgsgroup.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com


6. Dimension check

→ Sample size: [10pcs]

→ Reference document: [ISO4064-4:2014]

During this inspection, 10 samples were randomly selected for dimension check according to client's requirement. The details are as following.

Samples serial No. 2026061307, 2026061310, 2026062864, 2026062865, 2026063136, 2026063140, 2026065401, 2026065402, 2026065997, 2026065998.



Unit: mm

	Overall length L	Width W1, W2	Height H1	Height H2
Required	260 0/-2	Max. 100	Max. 65	Max. 260
Checked	259.17-259.66	50.3	41	121
	Thread of water meter	Length of thread	Length of pulse line	/
Required	/	Min. 12	2000	
Checked	Ok with G1-1/4-11 ring thread gauge	15.0~15.8	2100~2105	

Remark: the result is satisfactory.

7. Witness testing

During this inspection, samples were selected randomly for testing. The details are as following.

Test medium: Water, 20°C.

7.1 Water meter performance test



SGS-CSTC (Shanghai) Inspection & Testing Services Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.
This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No.1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040
t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

- Samples size: 10samples
- Reference document: [ISO4064-2:2014]

7.1.1 Static hydraulic pressure test:

Size	Serial No.	Test Pressure	Test Duration	Result
DN25	2026061307, 2026061310, 2026062864, 2026062865, 2026063136, 2026063140, 2026065401, 2026065402, 2026065997, 2026065998	1.6*MAP =2.56MPa	1Min	No visible leakage

7.1.2 Measurement error test

Flow rate point	Flow rate	Permissible error	Result	Detailed results
Q ₄	7.875m ³ /h	±2%	-1.62%~-0.01%	See attachment
Q ₃	6.3m ³ /h	±2%	-1.94%~0.15%	
Q ₂	0.063m ³ /h	±2%	-0.4%~+0.8%	
Q ₁	0.039m ³ /h	±5%	-3.9%~-1.2%	

Note: the water pressure in upstream was 0.5MPa.

7.1.3 Pressure loss test:

Size	Serial No.	Pressure loss (Bar)	
		at Q ₃ =6.3m ³ /h (Max. 0.63Bar)	at Q ₄ =7.875m ³ /h (Max. 0.80Bar)
DN25	2026061307	0.39	0.63
	2026061310	0.40	0.59
	2026062864	0.39	0.60
	2026062865	0.40	0.59
	2026063136	0.41	0.62
	2026063140	0.39	0.59
	2026065401	0.41	0.60
	2026065402	0.41	0.61
	2026065997	0.41	0.61
	2026065998	0.41	0.60

Remark: the result is satisfactory

7.2 Pulse sending test

- Samples size: above 10samples



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.
This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040
t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

Test result: a pulse receiver connected to the meter to monitor pulse from water meter, when every 1L water was counted by the water meter, a pulse sent by the water meter was recorded by the receiver. Total 100L water were used to test in every sample.

Remark: the result was acceptable according client's requirement 1 pulse/L.

7.3 Test for protection against water indicated by the second characteristic of IP68

→ Samples size: 5samples

Test procedure:

Samples completely immersed the enclosure in water.

The lowest point of enclosures is located 1100mm below the surface of the water.

Test duration is 1 hour.

After above test, Check for water inside beneath the glass dial and the pulse function.

Distance under water	Test duration	Test finding
1100mm	1 hour	1. No water was observed inside beneath the glass dial. 2. Pulse function was normal.

Samples serial No. 2026063136, 2026065402, 2026061307, 2026065997, 2026062864.

• Standard witnessing/observing disclaimer (voluntary witnessing)

In accordance with Client's instructions, the Company's involvement has been limited to witnessing/observing a third party's intervention(s) at the third party's laboratory/test house or other facilities and installations used for the intervention(s). The Company's sole responsibility was to be present at the time of the third party's intervention(s) to forward the results, or confirm the occurrence, of the intervention(s). The Company is not responsible for the condition or calibration of apparatus, instruments and measuring devices used, the analysis methods applied the qualifications, actions or omissions of the third party's personnel or the analysis results.

• Standard witnessing/observing disclaimer (regulatory witnessing)

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

8. Document review

Following documents are submitted by manufacturer.

- Quality management system ISO9001:2015 certificate (certificate No. 00124Q32620R7M/3302) valid until April 15, 2027.
- MID certificate No.SK14-098 MI-001 Rev4, the type of above meter is mentioned in this certificate, and it is valid until 10 Oct., 2033.
- Certificate of IP6X compliance of water meter model MD-K DN25, certificate No. CTSL2620730049SZ.
- Material test report. The main data in the report is in below table.



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC (Shanghai) Technical Services Co., Ltd.
Inspection & Testing Services

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040

t (86-574) 8776 7006 www.sgsgroup.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

Composition	Cu (%)	Pb (%)	As (%)	Al (%)	Zn (%)
Requirement	62.0-64.0	0.2-1.6	0.04-0.14	0.5-0.7	Remainder
Record	62.6011	0.822	0.1009	0.5461	35.7609
Composition	Fe (%)	Mn (%)	Ni (%)	Sn (%)	/
Requirement	≤0.3	≤0.1	≤0.1	≤0.3	
Record	0.0766	0.0083	0.0296	0.0337	

Note: the requirement of chemical composition is according to manufacturer's requirement.

Remark: the result is satisfactory.

Attachment: Details of measurement-error test

No.	Measurement Error (%)				
	Q ₃ /Q ₁ =160	Q ₄ (7.875m ³ /h)	Q ₃ (6.3m ³ /h)	Q ₂ (0.063m ³ /h)	Q ₁ (0.039m ³ /h)
	Serial No.	100L	100L	10L	10L
1	2026061307	-0.73	-0.62	0.5	-2.0
2	2026061310	-1.17	-1.94	0	-2.4
3	2026062864	-0.22	0.09	0	-3.0
4	2026062865	-0.22	-0.09	-0.4	-3.9
5	2026063136	-1.41	-1.30	0.3	-2.5
6	2026063140	-0.01	0.15	0.7	-2.1
7	2026065401	-1.52	-1.36	0.1	-2.1
8	2026065402	-0.80	-0.69	0.3	-2.8
9	2026065997	-1.62	-1.24	0.1	-2.4
10	2026065998	-1.19	-1.04	0.8	-1.2



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Inspection & Testing Services (Ningbo) Co., Ltd.
Industries Service

No.1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com

9. Photos



Fig 1. Plywood cases in mill



Fig 2. Plywood cases in mill



Fig 3. Cartons and Plywood cases in mill



Fig 4. Cartons in case



Fig 5. Side marking in carton



Fig 6. Open carton, two inner boxes



SGS-CSTC (China) Technical Service (Ningbo) Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com



Fig 7. Open inner box




Fig 8. A set of connector, manuals and water meter



Fig 9. Spare parts




Fig 10. Spare parts



Fig 11. Spare parts



Fig 12. A set of spare part



SGS-CTC (China) Technical Services (Ningbo) Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006

www.sgsgroup.com.cn

t (86-574) 8776 7006

sgs.china@sgs.com



Fig 13. Meter and connectors



Fig 14. Inlet




Fig 15. Meter fit with connectors



Fig 16. Dimension check




Fig 17. Dimension check – cable length



Fig 18. Thread check



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.
This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No.1177, LingyunRoad, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040
t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com



Fig 19. Static hydraulic pressure test



Fig 20. Measurement-error test




Fig 21. Pressure loss of pipe




Fig 22. Pressure loss test



Fig 23. Pressure loss test at Q₃




Fig 24. Pressure loss test at Q₄



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC (Shanghai) Technical Service (Ningbo) Co., Ltd.
Industries Service

No.1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com



Fig 25. Pulse sending test




Fig 26. Test for protection against water IP68

EU - TYPE EXAMINATION CERTIFICATE

No. SK 14 - 098 MI-001 Rev. 4

This revision replaces all previous versions of this Certificate in full wording

Issued by: **Slovenská lekárná metrologia, n. o.** Notified Body number **1432**
Geological 9999/1, 821 06 Bratislava-Podunajské Biskupce, Slovak Republic

Products certification body: **Hviezdoslavova 31, 074 01 Banská Bystrica, Slovak Republic**

In accordance with: **Annex II, Module B to Regulation of the Government of the Slovak Republic No 145/2016 Coll. on making available of measuring instruments on the market, in the wording of the Regulation of the Government of the Slovak Republic No 326/2019 Coll., which implements, in Slovakia, the Directive 2014/52/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of measuring instruments as later amended (MID).**

Applicable essential requirements: **Annex I and Annex III to MID**

Manufacturer: **Ningbo Aimei Meter Manufacture Co., Ltd., 88, West Town Road, Shangtian Town, Fenghua, Zhejiang, China 315511**

Applicant: **manufacturer**

Measuring instrument: **Water meter**

Type: **MD-K, MD-KP, MD-K1, MD-KP1**

Trade mark: **see Descriptive annex**

Environment classes:
- climatic: **(-10 to 55)°C**
- mechanical: **M1**
- electromagnetic: **E1**

Description and documentation: **The principal technical and metrological data, characteristics, instrument description and approval conditions are set out in the Descriptive annex to this EU - type examination certificate (22 pages), which is part of this EU - type examination certificate. The test reports, designs, schematic diagrams and documentation used during certification process are stored in the reference folder Ningbo Aimei_MD-K_KP_K1_KP1_00 to 04.**

Valid until: **10 October 2023**

Date of issue: **11 February 2025**

Ing. Dusan Smigura, PhD.
Representative of Notified Body

Where the instrument is subject to other Directives covering other aspects, this EU - type examination certificate is valid, assuming that the instrument conforms to the provisions of those Directives. Without written permission of the notified body this certificate may be reproduced only as a whole.

PK05-41

Fig 27. MID certificate

QUALITY MANAGEMENT SYSTEM CERTIFICATE

Certificate No. 00124Q32620R7M3302

We hereby certify that

Ningbo Aimei Meter Manufacture Co., Ltd.
Business Registration Number: 91330281449151758
No. 68, West Town Road, Shangtian Town, Fenghua District, Ningbo, Zhejiang, China

by reason of its

Quality Management System

has been awarded this certificate for compliance with the standard

ISO 9001:2015

The Quality Management System Applies in the following area:

The Design, Production and After Sales Service of Water Meter with Diameter 75mm and Below 200mm for Civil

Certified since: **July 24, 2000** Valid from: **April 7, 2024** Valid until: **April 15, 2027**

After a surveillance cycle, the certificate is valid only when used together with an Acceptance Notice of Surveillance Audit issued by CQC.

Please access www.cqc.com.cn to the checking validity of the certificate.

This certificate and its relevant information, like query is the website of Certification and Accreditation Administration of the People's Republic of China (www.ccaa.gov.cn).

IAF CNAS 中国合格评定国家认可委员会

谢肇熙

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nanxinshun Xilu, Beijing 100070 P. R. China <http://www.cqc.com.cn>

2024年版

Fig 28. ISO 9001 certificate



SGS-CSTC (Shanghai) Technical Services (Ningbo) Co., Ltd.
Industries Service

The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮箱: 315040

t (86-574) 8776 7006 www.sgsgroup.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com




Fig 29. Certificate of compliance of IP6X




Fig 30. Attachment of Certificate of compliance of IP6X (partial page)

THIS REPORT ONLY REFLECTED OUR ACTUAL FINDINGS. THE INSPECTION WAS DONE TO THE BEST OF OUR KNOWLEDGE AND ABILITY AND WITH DUE CARE. THE FINDINGS ARE VALID AS FOR TIME AND PLACE OF INSPECTION.

Issued by:	Angus Zhou	Reviewed by:	Kevin Peng	Approved by:	Michael Xie
Title or position:	Inspector	Title or position:	Coordinator	Title or position:	Inspection Manager
Date:	Jun. 05, 2026	Date:	Jun. 05, 2026	Date:	Jun. 05, 2026

End of Report



The report would be invalid without authorized signature. The report shall not be reproduced except in full, without written approval of the Company.

This document is issued by the Company under its General Conditions of Service accessible at <https://www.sgs.com/en/terms-and-conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 1177, Lingyun Road, Hi-Tech Zone, Ningbo, Zhejiang, China 315040
中国·浙江·宁波高新区凌云路1177号 邮编: 315040

t (86-574) 8776 7006 www.sgs.com.cn
t (86-574) 8776 7006 sgs.china@sgs.com