

ঢাকা ওয়াসা

সংযুক্ত ক্র: নং-১। ২০২২-২৩ অর্থ বছরের সাপাশো ফেজ-১ এর অনুমোদিত ক্রয় পরিকল্পনার কপি।

সংযুক্ত ক্র: নং-২। নথি অনুমোদনের কপি।

সংযুক্ত ক্র: নং-২। ২০২২-২৩ অর্থ বছরের সাপাশো ফেজ-১ এর সংশোধিত অনুমোদিত ক্রয় পরিকল্পনার কপি।

সংযুক্ত ক্র: নং-৩। ২০২৩-২৪ অর্থ বছরের সাপাশো ফেজ-১ এর অনুমোদিত ক্রয় পরিকল্পনার কপি।

বিষয়- Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing system at Saidabad Water Treatment Plant(Phase-1) শীর্ষক কাজের খাত সংশোধন অনুমোদন প্রসংগে।

১। সায়েদাবাদ পানি শোধনাগার (ফেজ- ১) ২০০২ সালে চালু হয়। প্লান্টটি পরিচালনায় ৪.৪ মেগাওয়াট জেনারেটর পাওয়ার প্লান্ট এবং ডিপিডিসির নারিন্দা সাব স্টেশন ও বর্তমানে মানিকনগর সাবস্টেশনের ১১ কেভি সংযোগের মাধ্যমে প্লান্টে পাওয়ার সরবরাহ করা হয়। বর্তমানে সায়েদাবাদ পানি শোধনাগার (ফেজ- ১) ম্যানুয়াল বা সেমি অটোমেটিক টেকনোলজি হতে শতভাগ স্কাডা অপারেটেড ভাবে পরিচালনার কার্যক্রম চলমান রয়েছে। ভোল্টেজ আপ ডাউনে স্কাডা কন্ট্রোলে স্থাপিত লো ভোল্টেজ মডিউল, সেনসর, কমিউনিকেশন ক্যাবল, সার্ভারের বিভিন্ন সিগনাল ইকুপমেন্ট সমূহ সুরক্ষার্থে ২০২২-২৩ অর্থ বছরে অনুমোদিত ক্রয় পরিকল্পনার মূলধন অংশের অটোমেশন ও ডিজিটাইজেশন খাতের থোক বরাদ্দ হতে ব্যয় নির্বাহ করা হবে বিবেচনায় আলোচ্য Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing system at Saidabad Water Treatment Plant(Phase-1) সরবরাহ কাজটি সম্পন্ন করার কার্যক্রম গ্রহণের জন্য ব্যবস্থাপনা পরিচালক হতে অনুমোদন নেয়া হয়। গত ১৪/০১/২০২৪ ইং তারিখে ঠিকাদার কাজটি সম্পন্ন করে। এখানে উল্লেখ্য, কাজটি স্কাডা কন্ট্রোলার অংশ হিসেবে করা হচ্ছে বিবেচনায় ২০২২-২৩ অর্থ বছরে সংশোধিত ক্রয় পরিকল্পনা এবং চলতি অর্থ বছরের ২০২৩-২৪ অর্থ বছরের ক্রয় পরিকল্পনার মূলধন অংশের স্কাডা স্থাপন খাতে অর্থের সংস্থান রেখে ক্রয় পরিকল্পনা যথাযথ কর্তৃপক্ষ কর্তৃক অনুমোদন নেয়া হয়েছে।

২। এমতাবস্থায়, কর্তৃপক্ষের কাজের স্বার্থে Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing system at Saidabad Water Treatment Plant(Phase-1) সরবরাহ কাজটি সায়েদাবাদ পানি শোধনাগার (ফেজ- ১), পরিচালন বিভাগ এর মূলধন অংশের অটোমেশন ও ডিজিটাইজেশন খাতের পরিবর্তে মূলধন অংশের স্কাডা স্থাপন খাত হতে ব্যয় নির্বাহের অনুমোদন দেয়া যেতে পারে। সদয় উপস্থাপন করা হল।

মোহাম্মদ শরিফ মাহমুদ
উপ-সহকারী প্রকৌশলী
সায়েদাবাদ পানি শোধনাগার (পরিচালন)
ঢাকা ওয়াসা।

মোহাম্মদ জসিম উদ্দিন
সহকারী প্রকৌশলী
সায়েদাবাদ পানি শোধনাগার (পরিচালন)
ঢাকা ওয়াসা।

মোঃ আবিদ হোসেন
নির্বাহী প্রকৌশলী
সায়েদাবাদ পানি শোধনাগার (পরিচালন)
ঢাকা ওয়াসা।

মিজা গোলাম কিবরিয়া
তত্ত্বাবধায়ক প্রকৌশলী
পাওপাশো সার্কেল, ঢাকা ওয়াসা।

মুস্তাফিজুর রহমান
প্রধান প্রকৌশলী
ঢাকা ওয়াসা

৬/ ২২-২৩ মাসের অনুমোদন
(৫৩৬) (১৫৬) (১৫৬)

একঃ এ.কে.এম. সহিদ উদ্দিন
ব্যবস্থাপনা পরিচালক (পরিচালন ও রক্ষণাবেক্ষণ)
ঢাকা ওয়াসা।

প্রকৌঃ তাকসিম এ খান
ব্যবস্থাপনা পরিচালক
ঢাকা ওয়াসা।

[View All Notifications](#)

Workflow History

[Go back to Dashboard](#)

Tender/Proposal Detail

Tender/Proposal ID :	763769	Invitation Reference No. :	46.05.0000.430.07.220.22-23/T-114
Closing Date and Time :	05-Jan-2023 12:00	Opening Date and Time :	05-Jan-2023 12:00
Procuring Entity :	Office of the EE, SWTP (operation) Division, Dhaka WASA		
Brief :	Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing Sub-Station at Saidabad Water Treatment Plant(Phase-1).		
Tender/Proposal Status :	NOA Issued		

[View Notice](#)

S.No	Processed By	Processed Date and Time	Comments	Action	
1	Taqsem A Khan - Managing Director	23-Jan-2023 19:33:36	View	Approved	Md. Kai
2	Md. Kamrul Hasan - Chief Engineer	10-Jan-2023 12:16:22	View	Forwarded	Taqsem

Page 1 of 1 10 ▼





DHAKA WATER SUPPLY AND SEWERAGE AUTHORITY

98 Kazi Nazrul Islam Avenue, Kawran Bazar,
Dhaka-1215

Purchase Order

ERP WO No	: Dhaka WASA/WO/MN//23/0998	ERP WO Date	: 18/12/23
Purchase Order No	: 46.113.430.00.00.07.220.2022-23.158	Purchase Order Date	: 28/02/23
Contract No	: 46.05.0000.430.07.220.2022-23/e-NOA-130	Contract Date	: 20/02/23
Supplier Name	: M/S. Shajeda & Co.	Delivered Store	: Saidabad Water Treat.Plant (Operation)
Supplier Address	: 16 Kawran Bazar (2nd Fl),Ambar Shah Shahi Masjid Market, Dhaka-1217	Procurement Division	: Saidabad Water Treat.Plant (Operation)
Installment	:	Name Of The Works	: Supply of 11KVA Automatic Voltage Regulator(AVR) with necessary arrangement of AVR Installation & Commissioning in Existing System with SCDA compatible at Saidabad Water Treatment Plant.

SL	Product Name	UoM	Country	Brand	Quantity	Unit Price	Amount(BDT)
1	SINGLE PHASE AUTOMATIC VOLTAGE REGULATOR (AVR) 11 KV 219A (3*6.35KV)	SET	United States	SIMENS	1	2,76,50,000.001	2,76,50,000.001
Total :					1.00		2,76,50,000.001

Prepared By

Signature : 

Name : MUHAMMAD SHARIF MAHMUD

Department : Saidabad Water Treat.Plant (Operation)

M/S. SHAJEDA & CO

16, Kawran Bazar, Ambar Shah Shahi Masjid Market (2nd Floor), Dhaka-1215.
All kinds of Construction, Development, Supplies, Exporter, Importer.

Dated: 12.11.2023

To
The Executive Engineer
Saidabad Water Treatment Plant (Operation)
Dhaka WASA.



Subject: Regarding the delivery of goods of the work "Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing Sub-Station at Saidabad Water Treatment Plant (Phase-1)".

Ref: 1. Contract Agreement No: 46.05.0000.430.07.220.22-23/NOA-130 Date: 20/02/2023
2. Work Order No: 46.113.430.00.00.07.220.2022-23.158 Date: 28/02/2023

Dear Sir,

With the above subject and reference we would like to inform you that, we have submitted the goods for the work. are being informed that against the job "Supply of 11KVA Automatic Voltage Regulator (AVR) with necessary arrangement of AVR Installation & Commissioning in Existing Sub-Station at Saidabad Water Treatment Plant (Phase-1)" on today on 12/11/2023. The details of goods are given below:

Item No.	Description Of Items	Quantity
01.	Supply of 11 KV 219A (3*6.35KV) Single Phase Automatic voltage regulator (AVR) Brand: SIEMENS, made in USA.	01 Sets

Therefore, you are specifically requested to deposit the goods.

Thanking you,

M/S. SHAJEDA & CO.

Proprietor

Farazy Md. Ariful Islam.
Proprietor
M/S. Shajeda & Co.

Handwritten notes and signatures: SAE (3), 12/11/23, AB, 12/11/23, S.K. 12.11.23.

1 set 11 KV 219A (3*6.35 KV) single phase AVR phase-1
12/11/23
12/11/23

SIEMENS

Test observations during energization or commissioning

CUSTOMER: Saidabad Water treatment plant

Dhalpur, Saidabad, Dhaka

Instrument: 1) Insulation tester (megger) 5000V, 1000 Gega ohms KYRITSU BRAND

Date of Measuring & Test: 14.01.2024

LC No. 411011878107-G, Bangladesh Bank DC Reference Number: 249023010310

Bill of Lading No. IAHA31056, Dated 20th July'23, DANMAR LINES

INSULATION/MEGGER TEST REPORT

Voltage Regulator single phase type JFR Serial No 1082185 -01 (phase 01)

Voltage Regulator single phase type JFR Serial No 1082185 -02 (phase 02)

Voltage Regulator single phase type JFR Serial No 1082185 -03 (phase 03)

Phase 01	Line	TO	BODY	7.64 GEGA OHMS
Phase 02	Line	TO	BODY	6.94 GEGA OHMS
Phase 03	Line	TO	BODY	6.03 GEGA OHMS


Voltage visibility check at LT panel after AVR commissioning.

Phase 01 to phase 02 439 VAC

Phase 02 to phase 03 438 VAC

Phase 03 to phase 01 437 VAC

Above mentioned report is satisfactory.


TESTED BY

A.K.M. Saifur Rahaman


Witness by