

কারিগরি পরীক্ষণ ও গ্রহণ প্রতিবেদন

বিষয় : Supply of 02 Nos Air Blower Set for Pre-Treatment plant (METEOR) of SWTP-2, DWASA.
সূত্র : (১) কন্ট্রাক্ট নং- 46.113.635.00.00.2025-26.162.125, Date- 30/10/2025
(২) কার্যাদেশ নং- ৪৬.১১৩.৬৩৫.০০.০০.২০২৫-২৬.১৬২.৪৫৫, তারিখ- ২৭/১১/২০২৫ইং
ঠিকাদারের নাম : Hammerhead Bangladesh Engineering Services Ltd.
সরবরাহের তারিখ : ২৫/০৬/২০২৬ ইং ।
সরবরাহের স্থান : সায়েদাবাদ পানি শোধনাগার ফেজ-২, ঢাকা ওয়াসা ।
পরিদর্শনের তারিখ : ২৮/০৬/২০২৬ ইং ।

Item No		Quantity
1.	Complete Air Blower Set for wastewater treatment plant Capacity: 6454 Nm ³ /h $\pm$ 3% @ differential pressure 640 mbar Motor: 200 KW, 50 Hz. Dimension: Width- 2550 mm, Length- 2793 mm, Height- 2460 mm Brand: ROBUSCHI es 145 / 5 C	02 Nos

সরবরাহকারী স্বাক্ষর

গ্রহণকারী স্বাক্ষর J. Karim

কারিগরি পরীক্ষণ কমিটির বাস্তব (ফিজিক্যাল) পরিদর্শন প্রতিবেদন ও স্বাক্ষরঃ

কারিগরি পরীক্ষণ কমিটি কর্তৃক মালামাল পরিদর্শন করা হ'ল এবং তা বাহ্যিক ভাবে সঠিক পাওয়া গেল। সরবরাহকৃত মালামাল সমূহ সিডিউলে উল্লেখিত স্পেসিফিকেশন মোতাবেক সঠিক পাওয়ায় সমুদয় মালামাল কারিগরি পরীক্ষণ কমিটি কর্তৃক গ্রহণ করা হ'ল।

সুজন চন্দ্র বর্মণ
নির্বাহী প্রকৌশলী
সাপাশো ফেজ-০২ (ওএন্ডএম) বিভাগ
ঢাকা ওয়াসা।

মোঃ নওশাদ আলম
নির্বাহী প্রকৌশলী
এফ এম বিভাগ-০১
ঢাকা ওয়াসা।

মিজা গেলিম কিবরিয়া
তত্ত্বাবধায়ক প্রকৌশলী
পাওপশো সার্কেল
ঢাকা ওয়াসা।

TÜV Rheinland Italia S.r.l.	INSPECTION RELEASE NOTE	 TÜVRheinland® Precisely Right.
Report No.:	TRI/30231/HBESL/IRN/001	Date of Inspection: 08.05.2026
Inspector:	Mr. Alessandro Ranieri	Page: 1 of 4


Project name:	Executing Country:
Municipal Sewage Treatment Plant	Bangladesh
Client: Hammerhead Bangladesh Engineering Services Ltd.	PO No.: PO-A25030231
Contact: Mr. Satyajit Roy	Ref / Order No.: 240326
Vendor/Manufacturer: ETS/Gardner Denver SRL – Divisione Robuschi	Vendor's Ref: IR2025110078 / 6077425
Contact: Mrs. Sonia Vecchi	Place of Inspection: Parma (Italy)
Attendees: Mrs. Sonia Vecchi	Date of Inspection: 8th May 2026
Assembly Group/Type Series:	Robuschi Air Blowers for EPT treatment plant Model ES 145/5.0C-RVP300-PED
Component:	Qty 2 – serial nr.2604470 and 2604471
Scope of Delivery	Pre-shipment

Released for:

Further processing:	☐	For packing:	☒	For shipment:	☒
----------------------------	--------------------------	---------------------	-------------------------------------	----------------------	-------------------------------------

1. Dates of Delivery: 1.1. Date of delivery according to PO: 12-14 weeks from 15.11.2025 ex work, Parma - Italy 1.2. Ultimate date of delivery as promised by supplier: week 20/2026 (ending 15 May 2026)
2. Check of Examinations: 2.1 ☐ Check of Material Certificates 2.2 ☐ Balance Test Certificates 2.3 ☐ Hydrostatic Test Certificate 2.4 ☐ Performance Test 2.5 ☐ Final Inspection before Packing 2.6 ☐ Storage, Handling and Packing 2.7 ☒ Documentation Control/Visual examination
3. Scheduled Dates: 3.1 Date of Final Inspection: 8th May 2026 3.2 Export Packing Date: not advised 3.3 Date of Shipment: not advised 3.4 Arrival at Destination: not advised
4. Remarks: Robuschi to proceed with packing activities, Invoice and final packing list issuance

TÜV Rheinland Italia S.r.l.	INSPECTION RELEASE NOTE	 TÜVRheinland® Precisely Right.
Report No.:	TRI/30231/HBESL/IRN/001	Date of Inspection: 08.05.2026
Inspector:	Mr. Alessandro Ranieri	Page: 2 of 4

Date: 8 th May 2026	Signature: 
--------------------------------	---


Disclaimer:
This report reflects our findings during inspection in time and place according to the agreed scope of our performance or deliverables and does not release buyer and/or seller from their contractual responsibilities. This report does not construe any guarantee or warranty that the purchase contract between buyer and seller is fulfilled correctly and all performances have been delivered without any defect. Furthermore, the report and its results does not affect any potential buyer's right to claim for compensation or remedy towards the seller/supplier of apparent or hidden defects not detected during our inspection or occurred afterwards.

PICTURES:

picture	description:
01: 	Air Blowers as presented
02: 	Back view

TÜV Rheinland Italia S.r.l.	INSPECTION RELEASE NOTE	 TÜVRheinland® Precisely Right.
Report No.:	TRI/30231/HBESL/IRN/001	Date of Inspection: 08.05.2026
Inspector:	Mr. Alessandro Ranieri	Page: 3 of 4

03:





Safety valves serial numbers

4.



Internal view, no damages

TÜV Rheinland Italia S.r.l.	INSPECTION RELEASE NOTE	 TÜVRheinland® Precisely Right.
Report No.:	TRI/30231/HBESL/IRN/001	Date of Inspection: 08.05.2026
Inspector:	Mr. Alessandro Ranieri	Page: 4 of 4

5.  	Robuschi tag plates
--	----------------------------