



ঢাকা পানি সরবরাহ ও পয়ঃ নিষ্কাশন কর্তৃপক্ষ

নির্বাহী প্রকৌশলীর কার্যালয়

এফ, এম, বিভাগ-২, ঢাকা ওয়াসা।


দারুস সালাম রোড, মিরপুর, ঢাকা -১২১৬।

টেলিফোন :- অফিসঃ সরাসরিঃ ০২-৪৮০৩১৯৫০, ০২-৪৮০৩১৬৪৬ মোবাইলঃ ০১৮৭৯-৮২৯৭০০

স্মারক নং- ৪৬.১১৩.৪২৪.০০.০০.২০২৬.

তারিখঃ ৩০.০৬.২০২৬ ইং

নির্বাহী প্রকৌশলী
সংগ্রহ বিভাগ-১
ঢাকা ওয়াসা।



বিষয়ঃ Procurement of VFD Spare Parts for Dhaka WASA কাজের গৃহীত মালামাল সমূহের এস. আর. আই. এন. প্রেরণ প্রসঙ্গে।

সূত্র : (১) চুক্তি নং ৪৬.১১৩.৪২৭.০০.০৪৯.২০২৫/সি-০৩, তাং-১৭.০২.২০২৬ইং, চুক্তি স্বাক্ষরের তারিখঃ ২৩.০২.২০২৬ইং
(২) কার্যাদেশ নং- ৪৬.১১৩.৪২৭.০০.০৪৯.২০২৫-১১৫৩, তাং-২৩/০২/২০২৬ ইং
(৩) স্মারক নং-৪৬.১১৩.৪২৭.০০.০৪৯.২০২৫-১৭২৯, তাং- ২৫/০৬/২০২৬ ইং

উপরোক্ত বিষয় ও সূত্র মোতাবেক সরবরাহকারী প্রতিষ্ঠান M/S.Faisal Enterprise কর্তৃক সরবরাহকৃত মালামালের এস.আর.আই.এন. (যার নং- MW26070014) তারিখঃ ৩০.০৬.২০২৬ ইস্যু করত এতদসঙ্গে প্রয়োজনীয় কার্যক্রম গ্রহণের জন্য প্রেরণ করা হলো।

সংযুক্তি: এস.আর.আই.এন. ১(এক) ফর্দ

(শেখ আরিফ রহমান জিতু)

নির্বাহী প্রকৌশলী

এফ,এম, বিভাগ-২, ঢাকা ওয়াসা।

অনুলিপি ৪ সদয় অবগতির জন্য

১। উপ-প্রধান হিসাব রক্ষণ কর্মকর্তা, হিসাব বিভাগ, ঢাকা ওয়াসা।

২। অফিস কপি।



DHAKA WATER SUPPLY AND SEWERAGE AUTHORITY

98 Kazi Nazrul Islam Avenue, Kawran Bazar,
Dhaka-1215

Store Receipt And Inspection Note

Purchase Copy

SRINo : MW26070014 **Supply Date** : 21/06/26
Divisional WO No : 46.113.427.00.00.049.2025-1153 **Contract No** : 46.113.427.00.00.049.2025/C-03
Deliver To : F M Division- 2 **Date** : 17/02/2026
Received From : M/S. Faisal Enterprise **Procuring Division**: Procurement Division - 1
Work Order id : Dhaka WASA/WO/MN//26/0881 **Inspection Date** :

SL	Description of Items	UoM	Order Quantity	Brand-Origin	Inspection Report		Accounts Department		
					Goods Accepted	Remarks	Unit Rate	Total Cost	Total BDT Cost
1	IGBT MODULE FOR 90KW VFD, PART NO: K77H03800006 CM400DY-24NF(6P) *OKADEN [F740-90K] MODEL: FR-F740P-90K (17015-0003)	NOS	25	mitsubishi-Japan	25		84,080.000	21,02,000.000	21,02,000.00
2	INPUT PROTECTION PLATE (3 PHASE), PART NO: K77H01500019 PWBA [FILTER CARD] PCBA74AX132B [F740-90K] MODEL: FR-F740P-90K (17015-0001)	NOS	24	mitsubishi-Japan	24		11,830.000	2,83,920.000	2,83,920.00
3	THREE WIRE COOLING FAN FOR 90KW VFD, PART NO: K09H30100004 MMF-12D24DS-RP1 BKO-CA22351125, MODEL: FR-F740P-90K (17015-0016)	NOS	25	mitsubishi-Japan	25		12,980.000	3,24,500.000	3,24,500.00
4	THREE WIRE COOLING FAN FOR 90KW VFD, PART NO: K09H30100015 MMF-12J24DS-CP1, MODEL: FR-F840-90K-1 (17015-0017)	NOS	25	mitsubishi-Japan	25		12,980.000	3,24,500.000	3,24,500.00
5	RECTIFIER DIODE FOR 90KW VFD DIODE MODULE, PART NO: 77H26200015 PD250KN16A * NIC (90K) [3 PCS IN 1 SET] MODEL: FR-F840-90K-1 (17015-0006)	NOS	20	mitsubishi-Japan	20		35,075.000	7,01,500.000	7,01,500.00
6	RECTIFIER DIODE FOR 90KW VFD DIODE MODULE, PART NO: K77H01200016 PD200S16 (FR-F740-90K) [3 PCS IN 1 SET] MODEL: FR-F740P-90K (17015-0005)	NOS	20	mitsubishi-Japan	20		35,075.000	7,01,500.000	7,01,500.00
7	LCD PARAMETER UNIT/KEYPAD FOR 90KW VFD DISPLAY UNIT, PART NO: K09H05000033 FR-DJ07 BKO-CA1633H13 *JAE MODEL: FR-F740P-90K (17015-0012)	NOS	25	mitsubishi-Japan	25		31,899.000	7,97,475.000	7,97,475.00
8	LCD PARAMETER UNIT/KEYPAD FOR 90KW VFD DISPLAY UNIT, PART NO: K09H68000002 FR-DJ08 BKO-CA2138 *JAE MODEL: FR-F840-90K-1 (17015-0013)	NOS	25	mitsubishi-Japan	25		31,899.000	7,97,475.000	7,97,475.00
9	MAIN CIRCUIT BOARD/ MOTHER BOARD/ CPU BOARD, PART NO:K09H51001498 A70CA560E [F740-90K] MODEL: FR-F740P-90K (17015-0010)	NOS	30	mitsubishi-Japan	30		65,360.000	19,60,800.000	19,60,800.00



DHAKA WATER SUPPLY AND SEWERAGE AUTHORITY

98 Kazi Nazrul Islam Avenue, Kawran Bazar,
Dhaka-1215

Store Receipt And Inspection Note

SL	Description of Items	UoM	Order Quantity	Brand-Origin	Inspection Report		Accounts Department		
					Goods Accepted	Remarks	Unit Rate	Total Cost	Total BDT Cost
10	CONTROL CIRCUIT (POWER DRIVER BOARD) PWBA [MA BOARD], PART NO: CK77H60200088, PCB A84MA90B-60 [F840-90K] MODEL: FR-F840-90K-1 (17015-0009)	NOS	20	MITSUBISHI-Japan	20		79,682.000	15,93,640.000	15,93,640.00
Total :			239	Total :	239			95,87,310.000	95,87,310.0

Store In-charge:

Prepared by : MD. KAMAL UDDIN : 3076

Inspected By:

1. Mashudul Alam : 6024, Executive Engineer (CC).
2. SK.ARIF RAHMAN JETU : 6049, Executive Engineer.
3. MD. ABDUL LATIF : 4578, Superintending Engineer.