

যৌথ পরিদর্শন প্রতিবেদন

কাজের নাম : Supply of different materials parts and related services for 15/11/7.5 KW sewage dewatering pump motor set under PSTP.

ঠিকাদারের নাম : মেসার্স আল ওয়াসি এন্টারপ্রাইজ

চুক্তিপত্র নং : ৪৬.১১৩.৪৩৩.০০.০০.২০২৫-২৬.২৭০-০২৭, তারিখঃ ১২/০৫/২০২৬ইং

মালামাল সরবরাহের তারিখ : ১০/০৬/২০২৬ ইং


পরিদর্শনের তারিখ : ১১/০৬/২০২৬ইং তারিখ বৃহস্পতিবার সকাল ১১.৩০ ঘটিকা।

পরিদর্শনের স্থান : পাগলা পয়ঃ শোধনাগার বিভাগীয় স্টোর।


ক্রঃ নং	মালামালের বিবরণ	সিডিউলে উল্লেখিত মালামালের পরিমাণ	জমাকৃত মালামালের পরিমাণ	গ্রহণযোগ্য মালামালের পরিমাণ
01.	19 SWG super enamel copper	91 Kg	91 Kg	91 Kg
02.	22 SWG super enamel copper	19 Kg	19 Kg	19 Kg
03.	nitto golden varnish	10 gallon	10 gallon	10 gallon
04.	leatheroid paper (heat-resistant)/No-max heat prove fiber.	20 meter	20 meter	20 meter
05.	Ampere/Silicon Tube 2, 3,4,5,6,8 size (heat-resistant).	80 meter	80 meter	80 meter
06.	Cotton Tape 1 Inch X 150 feet	10 dozen	10 dozen	10 dozen
07.	rung.	2 kg	2 kg	2 kg
08.	resin.	2 kg	2 kg	2 kg
09.	grease.	10 kg	10 kg	10 kg
10.	turbo oil.	40 liter	40 liter	40 liter
11.	PIB Tape (1"/50 yds, long)	10 each	10 each	10 each
12.	plastic tape.	20 each	20 each	20 each
13.	NC thinner (T-6)	20 liter	20 liter	20 liter
14.	oil seal (as per size and sample)	20 each	20 each	20 each
15.	ball bearing 7309 2RS SKF/FAG	20 each	20 each	20 each
16.	S.S check, nut (as per Size and Sample)	6 each	6 each	6 each
17.	neck ring (as per size and sample)	10 each	10 each	10 each
18.	Mechanical Seal (Model : Buk A22-06/240, Mgl/75-Z),	10 each	10 each	10 each
19.	S.S Shaft Sleeve (as per size and sample)	5 each	5 each	5 each
20.	Jam nut for impeller (as per size and sample)	2 each	2 each	2 each
21.	cable socket (95rm/70rm/50rm)	40 set	40 set	40 set
22.	Terminal loop.	4 meter	4 meter	4 meter
23.	Flexible terminal connection cable. Size 1C-4x10 rm	60 meter	60 meter	60 meter

যৌথ পরিদর্শন কমিটির বাস্তব (ফিজিক্যাল) পরিদর্শন : যৌথ পরিদর্শন কমিটি কর্তৃক মালামাল পরিদর্শন করা হল এবং তা স্পেসিফিকেশন অনুযায়ী সঠিক পাওয়া গেল। সরবরাহকৃত মালামাল সঠিক পাওয়ায় পরিদর্শন কমিটি কর্তৃক গ্রহণযোগ্য বলে বিবেচিত হল।


রিপোর্ট :-




ঠিকাদারের স্বাক্ষরঃ-
মেসার্স আল ওয়াসি
এন্টারপ্রাইজ।




(মোঃ মামুনুর রহমান)
উপ-সহকারী প্রকৌশলী
পাগলা পয়ঃ শোধনাগার বিভাগ
ঢাকা ওয়াসা।



(মোঃ হাসিবুল হাসান)
উপ-বিভাগীয় প্রকৌশলী
পাগলা পয়ঃ শোধনাগার বিভাগ
ঢাকা ওয়াসা।



(সৈয়দ শিহাবুর রহমান)
নির্বাহী প্রকৌশলী
পাগলা পয়ঃ শোধনাগার বিভাগ
ঢাকা ওয়াসা।



(মির্জা গোলাম কিব্রিয়া)
তত্ত্বাবধায়ক প্রকৌশলী
পানি ও পয়ঃ শোধনাগার সার্কেল
ঢাকা ওয়াসা।