

Form View

[Tender/Proposal Document](#)

Tender/Proposal Detail

Tender/Proposal ID :	1283388	Invitation Reference No. :	46.113.637.00.00.162.2026/Notice-129
Closing Date and Time :	28-Jun-2026 12:00	Opening Date and Time :	28-Jun-2026 12:00
Procuring Entity :	Office of the EE, Dasherbandi Sewage Treatment Plant, Dhaka WASA		
Brief :	Procurement of spare parts such as lubricating pump, seal, level sensor for plunger pump of Dasherbandi STP.		
Tender/Proposal Status :	NOA Issued		

[View Notice](#)

Is BOQ Form : No

Form Name : Technical Specifications and Compliance of Goods and related services (Form e-PG2-4)

Notes on Technical Specifications:

Note 1:

[A set of precise and clear specifications is a prerequisite for Tenderes to respond realistically and competitively to the requirements of the PE. In the context of Competitive Tender, the specifications must be prepared to permit the widest possible competition and, at the same time, present a clear statement of the required standards of workmanship, materials, and performance of the goods and services to be procured. Only if this is done will the objectives of transparency, equity, efficiency, fairness and economy in procurement be realized, responsiveness of Tenderes be ensured, and the subsequent task of Tender evaluation and post-qualification facilitated. The specifications should require that all items, materials and accessories to be included or incorporated in the goods be new, unused, and of the most recent or current models, and that they include or incorporate all recent improvements in design and materials]

Form Header :

Note 2:

[The PE must explain in clear terms the exact Technical Specification and any relevant National or International Standards which have to be followed for the manufacture and supply of the goods or related services. Technical Specifications shall specify what inspection and/or tests the PE requires and where they are to be conducted]

Note 3:

Keep the same Item no. in price schedule and technical specification form.

Item No.	Name of Goods	Detailed Technical Specification and Standards required	Inspection and/or tests required and test place	Country of Origin	Make, and Model or Brand (when applicable)	Full Detailed Technical Specifications and Standards offered
1	Lubricant Pump	Lubricant Pump for Plunger pump. Material: 45# steel, Volume: 4 litre, Voltage: 24VDC, Power: 60 Watt, Flow: 1.2ml/min, port: 5 nos.Brand: To be mention, Origin: Austria,Germany,Japan,USA, China.	As per PCC	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text
2	Main Control board	Main Control board for Ozone 90 kw Inverter Type:PCB001 NLOPS series converter. Inverter capacity: 90KW, Ozone Generation System.Brand: To be mention, Origin: Austria,Germany,Japan,USA, China..	As per PCC	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text
3	IGBT Driver	IGBT Driver for Ozone Inverter,Type:FF900R12IE4 NLOPS series converter.Inverter capacity: 90KW, Ozone Generation System.Brand: To be mention, Origin: Austria,Germany,Japan,USA, China.	As per PCC	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text
4	IGBT half-bridge module	IGBT half-bridge module for Ozone Inverter,Type:2SP0320TC0-12 NLOPS series converter.Inverter capacity: 90KW, Ozone Generation System. Brand: To be mention, Origin:Austria,Germany,Japan,USA, China.	As per PCC	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text	Fill By Tenderer/Consultant - Long Text

Table Footer : [The Tenderer should complete all the columns as required]

Existing Formula(s)

S. No.	Applied to Column	Formula
No Records Found		