



নির্বাহী প্রকৌশলীর কার্যালয়

সিষ্টেম অপারেশন এন্ড কন্ট্রোল (এস ও সি) বিভাগ, ঢাকা ওয়াসা।

পুরাতন এ্যালিফ্যান্ট রোড, (রমনা থানার পশ্চিম পার্শে), ঢাকা-১০০০।

ফোন : ৪৯৩৫৮১৯২ (অভিযোগ কেন্দ্র), ফোন : / ফ্যাক্স : ৪১০৩০৪২৪ (অফিস)।

e-mail: eesocdivi@gmail.com



শেখ হাসিনার মূলনীতি
গ্রাম শহরের উন্নতি

বিষয়ঃ যৌথ পরিদর্শন রিপোর্ট।

কাজের নাম	:	Supply and Installation of exhaust fan and others require fittings for chlorine room under SOC Division.
ঠিকাদারের নাম	:	M/S Losung Power Engineering
চুক্তি নং	:	46.05.0000.441.30.015.23.043 Date: 08/02/2024
কার্যাদেশ নং	:	46.05.0000.441.30.015.23.043 Date: 08/02/2024
প্রাক্কলিত মূল্য	:	৪,৯৯,৭৫৮.৫৩
চুক্তি মূল্য	:	৩,৭৪,৫৬০.৬৫৭ / = (তিন লক্ষ চুয়াত্তর হাজার পাঁচ শত ষাট দশমিক ছয় পাঁচ সাত) টাকা মাত্র।
সরবরাহের সময়সীমা	:	৯০ (নব্বই) দিন।
সরবরাহের তারিখ	:	১৫/০২/২০২৪ ইং
পরিদর্শনের তারিখ	:	২৫/০২/২০২৪ ইং

ক্রঃ নং	মালামালের বিবরণ	একক	চুক্তি অনুযায়ী মালামাল	সরবরাহকৃত মালামাল	গ্রহণযোগ্য মালামাল	বাতিলকৃত মালামাল
1)	VENTILATION FAN Suppy, installation, testing & commissioning of Fan including non return dams with all necessary accessories and fittings. Fixing for commissioning of the equipment including all electrical & Civil works as follows technical specification. drawing and time to time site instruction from Engineer-in-charge. Capacity:100 cfm, ESP 30 Pa	Each	15	15	15	0
2)	Concealed conduit wiring for Following point looping at the switch board with earth terminal with 1C-2x1.5 sqmm PVC insulated and sheathed stranded cable (BYM)& 1C-2x1.5 sqmm PVC insulated ECC (BYA) (Green/Yellow bi-colour)including circuit wiring with(form sdb to Switch Board) 1C-2x2.5 sqmm PVC insulated and sheathed stranded cable (BYM) & 1C-2x2.5 sqmm PVC insulated ECC (BYA) Green/Yellow bi-colour through PVC conduit (one conduit from switch board to common point on ceiling is considered to draw 3 pair of cable) of reputed manufacturer of minimum 25mm dia & 1.7 mm wall thickness complete with 18SWG GP sheet/PVC switch board &pull box with 3mm thickness complete with 18swg GP sheet/PVC switch board & pull box with 3mm thick ebonite sheet cover,without switch, fixing materials etc.(without switch) as required including mending the damages good. All electrical contacts shall be of brass/copper connected through connector or soldering (no twisting shall be allowed) and cables shall be manufactured and tested according to IEC/BS/VDE standards along with relevant BDS standard as per detailed specification mentioned in Annexure-1. The work shall be carried out as per direction & approval of the Engineer in charge.	meter	110	110	110	0
3)	Surface channel wiring with the following PVC insulated and sheathed stranded cable (BYM) & Green / Yellow bi-colour PVC insulated ECC wire (BYA), through minimum 1 mm thick PVC channel complete with fixing materials, other accessories etc. as required including mending the damages good. All electrical contacts shall be of brass / copper connected through connector or soldering (no twisting shall be allowed) and cables shall be manufactured and tested according to IEC / BS / VDE standards along with relevant BDS standard as per detailed specification mentioned in Annexure- I . The work shall be carried out as per direction & approval of the Engineer In Charge. I C-	meter	116	116	116	0

Signature

Signature

Signature

Signature



নির্বাহী প্রকৌশলীর কার্যালয়

সিস্টেম অপারেশন এন্ড কন্ট্রোল (এস ও সি) বিভাগ, ঢাকা ওয়াসা।

পুরাতন এ্যালিফ্যান্ট রোড, (রমনা থানার পশ্চিম পার্শে), ঢাকা-১০০০।

ফোন : ৪৯৩৫৮১৯২ (অভিযোগ কেন্দ্র), ফোন : / ফ্যাক্স : ৪১০৩০৪২৪ (অফিস)।

e-mail: eesocdivi@gmail.com





শেখ হাসিনার মূলনীতি
গ্রাম শহরের উন্নতি

	2x2.5 sqmm (BYM) cable with 2.5 sqmm (BYA) ECC wire					
4)	IC-2x4 sqmm (NYY) with 4 sqmm (BYA) ECC wire through the pVC pipe of minimum inner dia 25 mm & wall thickness 1.7 mm	meter	110	110	110	0
5)	GANG SWITCT{. Providing & fixing 250 volts.5 / 6 amps (minimum) concealed rype following switch / switch socket Manufactured / Assembled and tested in accordance with IEC / VDE / NEMA / BS / JIS along with relevant BDS IEC standards mounted on required size lg SWG galvanized plain sheer / PVC board (Self.extinguishing 650 Degree Centigrade) of 76.2 mm (3,) ll electrical contacts shall be ofbrass / copper	Each	15	15	15	0
6)	TPMCB: Providing & fixing on a prepared board 500 volt grade following Triple pole miniature circuit Breaker (TpMCB) having minimum breaking capacity 6-KA/ 10 KA with thermal over-current and instantaneous electromagnetic shon circuir release provision as per BDS IEC and IEC 1 VDE / NEMA / BS / JIS standard. 5-60Amps	Each	15	15	15	0
7)	Supply and fixing of PVC insulating tape. (UK / JAPAN or equivalent brand accepted / approved by the Engineer In Charge) 3/4" width PVC insulation tape (Nitto) (10 yards per reel)	Each	260	260	260	0
8)	Round panel (surface type) Material: Alu Aloy, Acrylic Gloria Cat No-GSDL-513 Energy=cat No-EPPLLED-2006 Cosmo cat no-BDTCL-LSRPL-01 Adex-AD SDL 830/840/865 Asha Cat no-ACS LPL-1451 Megaman-MXTL1013-Y Walton WLED-DSPLR-200-UL or equivalent. 24 W, Approximate Dia-297mm.	Each	15	15	15	0

মন্তব্যঃ Supply and Installation of exhaust fan and others require fittings for chlorine room under SOC Division. সরবরাহ কাজটির মালামাল ঠিকাদারী প্রতিষ্ঠান M/S Losung Power Engineering কর্তৃক সরবরাহ করা হয়েছে। মালামালসমূহ ফিজিক্যালি পরিদর্শন করে স্পেসিফিকেশন মোতাবেক সঠিক পাওয়া গিয়েছে, কাজেই যৌথ পরিদর্শন রিপোর্টটি গ্রহন করা যেতে পারে।


M/S Losung Power
Engineering


Rukh.
25/02/24
রুখানা পারভীন
উপ-সহকারী প্রকৌশলী
এস ও সি বিভাগ, ঢাকা ওয়াসা।


মোঃ আহসানুল খান
সহকারী প্রকৌশলী
এস ও সি বিভাগ, ঢাকা ওয়াসা।


25/02/2024
মোঃ নওশাদ আলম
নির্বাহী প্রকৌশলী
এস ও সি বিভাগ, ঢাকা ওয়াসা।


25/02/24
মোঃ ইকবাল আহমেদ মজুমদার
তত্ত্বাবধায়ক প্রকৌশলী
এস.এম.ডব্লিউ.সি সার্কেল, ঢাকা ওয়াসা।